



TOP VIEW

EXAMPLE OF UNACCEPTED INSTALLATION:



REASON: 3' X 3' FLAG NEEDS TO BE INSTALLED FOR BOTH THE STREET LIGHT AND THE PULL BOX.

RECOMMENDED BY:	DATE: 8/04/2020
APPROVED BY:	DATE:
PREPARED BY:	DATE:
SCALE: NTS	

TITLE: **PAVER STANDARD**



PUBLIC UTILITIES COMMISSION
POWER ENTERPRISE
 UTILITY SERVICES - STREET LIGHTING

DRAWING No.: 1 of 1
